



WorkSafe Western Australia
Occupational Safety and Health Act 1984

**REQUIREMENTS FOR CONSTRUCTION, TESTING AND
REGISTRATION OF PRESSURE EQUIPMENT FOR USE IN
WESTERN AUSTRALIA**

1. **CONSTRUCTION & TESTING** - Construction, welding and testing shall be in accordance with the requirements of the registered design and nominated standard.
2. **RECORDS OF CONSTRUCTION AND TESTING** - A completed Manufacturer's Data Report giving the information on materials, construction and testing required by the design Standard and certified by the Fabrication Inspector shall be supplied with each vessel manufactured to the registered design.
3. **VALVES & FITTINGS** - Valves, fittings and safety relief devices used in connection with a boiler or pressure vessel shall meet the requirements of the relevant Standards.
4. **INSPECTION PRIOR TO USE** - Prior to use in Western Australia,
 - 4.1 All boilers and pressure vessels shall comply with the inspection and registration requirements set out in the OSH Regulations 1996.
 - 4.2 All gas cylinders shall comply with the inspection requirements set out in the OSH Regulations 1996. Before filling, gas cylinders are required to be checked and stamped by a test station approved under the provisions of AS2337-Gas Cylinder Test Stations. (See list in MP48- Approved gas cylinder test stations).